



CATER-CLEAN
SOLUTIONS

catercleansolutions.co.uk

Work Completion Report

***** , *****





Kitchen Extraction Cleaning Report

Survey Date	
Senior Site Representative	Jack Smith – Senior Field Manager
Survey Company	Cater-Clean Solutions Limited
Report Print Date	14/12/2020
Report Authorised By	Jessica Scriven – Workplace Coordinator

Contact Information

Client	
Client Name	**** *
Client Address 1	***** *
Client Address 2	
City	Leeds
Post Code	**** *

Site Address

Client	
Client Name	***** *
Client Address 1	***** *
Client Address 2	
City	Leeds
Post Code	**** *



Fault Report

No faults were discovered within the system.

Access Report

FULL ACCESS

Correct access was installed prior to testing

Regulations

Our works were undertaken in accordance with the following legislation:

BS-EN:0852 & BESA TR/19 Standards - set out the industry benchmark in ventilation hygiene. All works completed are in compliance of these regulations and all works surveyed are done so ensuring that it is the expectation of the client to achieve a minimum standard equal to or greater than the parameters set out within.

British Standard En 15780: 2011 – Ventilation for buildings – ductwork – cleanliness of ventilation systems. ISBN 978 0 580 74008 4

BSRiA Facilities Management Series FMS1/1997 - Guidance to the specification for ventilation hygiene. ISBN 0860224546

BESA TR/19 Standards 2019 - Section 4 of TR/19 Standards outlines specific considerations for Air Handling Units which are more commonly referred to as “AHU’s”.



Kitchen Extraction System 01 –

System Risk Level	LOW
System Fault Warning	N/A



Canopy Hood

Pre Cleaning

Pre Clean Micron Reading: 600 μm



Canopy Hood

Post Cleaning

Post Clean Micron Reading: 0 μm



Canopy Hood

Pre Cleaning

Pre Clean Micron Reading: 600 μm



Canopy Hood


Post Cleaning

Post Clean Micron Reading: 0 μm



Kitchen Extraction System 01 -

System Risk Level	LOW
System Fault Warning	N/A



Discharge Ductwork

Pre Cleaning

Pre Clean Micron Reading: 12,000 μm



Discharge Ductwork

Post Cleaning


Post Clean Micron Reading: 0 μm



External Riser

Pre Cleaning

Pre Clean Micron Reading: 7,500 μm



External Riser


Post Cleaning

Post Clean Micron Reading: 0 μm



Kitchen Extraction System 01 -

System Risk Level	LOW
System Fault Warning	N/A



Discharge Ductwork

Pre Cleaning


Pre Clean Micron Reading: 8,000 μm



Discharge Ductwork

Post Cleaning

Post Clean Micron Reading: 0 μm



External Riser

Pre Cleaning

Pre Clean Micron Reading: 1,800 μm



External Riser

Post Cleaning

Post Clean Micron Reading: 0 μm



Kitchen Extraction System 01 -

System Risk Level	LOW
System Fault Warning	N/A




Discharge Ductwork
Pre Cleaning

Pre Clean Micron Reading: 12,000 µm



Discharge Ductwork
Post Cleaning

Post Clean Micron Reading: 0 µm



External Riser
Pre Cleaning

Pre Clean Micron Reading: 7,500 µm




External Riser
Post Cleaning

Post Clean Micron Reading: 0 µm



Kitchen Extraction System 01 –

System Risk Level	LOW
System Fault Warning	N/A



Discharge Ductwork
Pre Cleaning

Pre Clean Micron Reading: 21,000 µm



Discharge Ductwork
Post Cleaning

Post Clean Micron Reading: 0 µm





External Riser
Pre Cleaning

Pre Clean Micron Reading: 21,000 µm



External Riser
Post Cleaning

Post Clean Micron Reading: 0 µm





Advisory Notes:

There are no advisory notes at this stage

Cleaning Frequency Chart

Perceived level of grease production	Typical Example	Cleaning Intervals (Months) Daily Usage			
		Up to 6 Hours	6-12 Hours	12-16 Hours	16+ Hours
Low	No significant production of grease laden aerosols during normal daily food production operations	12	12	6	6
Medium	Moderate production of grease laden aerosols during normal daily food production operations	12	6	4	3
High	Heavy, significant or continual production of grease laden aerosols during normal daily food production operations	6	3	3	2



CATER-CLEAN SOLUTIONS



Kitchen Extraction Cleaning Certificate

Certificate Number

0000 / DC8729-21341 / 01734

This is to certify that the following services have been performed upon the ventilation system listed below

Cleaned	<input type="checkbox"/>	Inspected	<input type="checkbox"/>
Disinfected	<input type="checkbox"/>	Tested	<input checked="" type="checkbox"/>

Client *****

Site Address *****

Area: *****

Average pre cleaning micron reading: N/A

Certification Date: 14/12/2020

Next Inspection Due: 14/01/2021

x 